intertek
Total Quality. Assured.

AUTHORIZATION TO MARK

This authorizes the application of the Certification Mark(s) shown below to the models described in the Product(s) Covered section when made in accordance with the conditions set forth in the Certification Agreement and Listing Report(s). This authorization also applies to the Multiple Listee model(s) identified on the correlation page of the Listing Report.

This document is the property of Intertek Testing Services and is not transferable. The Certification Mark(s) may be applied only at the location of the Party Authorized to Apply Mark.

Applicant:	Anhui Meilin Kaidi Wood Industry Co., Ltd No 1 Road, Yingjiang Industrial Park Yingjiang District Anqing City, Anhui Province 246008 China
Contact:	Yu Yue
Phone:	(+86) 1995-5613652
Email:	yy_809@outlook.com
Party Authorized to Apply Mark:	See following page(s)
Evaluation Center:	Intertek (Shanghai)
Client Number:	459339

Authorized By:
Jean-Philippe Kayl, Director of Certification

Intertek Testing Services NA, Inc.
545 E. Algonquin Road, Ste H., Arlington Heights, IL 60005 USA
Phone: 847-439-5667 Fax: 847-439-7320

C US
Intertek

This document supersedes all previous Authorizations to Mark for the noted Report Number.

This Authorization to Mark is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Authorization to Mark. Only the Client is authorized to permit copying or distribution of this Authorization to Mark and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement and in this Authorization to Mark. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

Testing Standard(s):	CAN / ULC S104 (2015) (R2020), UL 10(b) (2008) (R2020), UL 10(c) (2016) Ed. 3 (R:27 May 2021), NFPA 252 (2022)
Product:	Anhui Meilin Kaidi - 90 Minute Single Leaf Steel Fire Door (Model GFM-MLKDas-L-1224 A90Mins)

ATM for Spec Id: 91995 **ATM Issue Date:** 8/20/2026

Listing Section(s): CATEGORY B - DOORS - ADDITIONAL EDGE-SEALING SYSTEM REQUIRED

CSI Code(s): 08 10 00 Doors and Frames

Description:

FIRE RESISTANT PRODUCTS & COMPONENTS
CATEGORY B DOORS – ADDITIONAL EDGE-SEALING SYSTEM REQUIRED
A surface applied to frame Category G intumescent edge seal system is required.

PRODUCT COVERED
Anhui Meilin Kaidi - 90 Minute Single Leaf Steel Fire Door
Door Model: GFM-MLKDas-L-1224 A90Mins

PRODUCT DESCRIPTION

Hardware Limitations:
Listed Mortise Locks or Cylindrical Locks with minimum latch bolt throw of 1/2".
Minimum one single point standard latching on the leaf.

Configuration	Maximum Size
Single Swing	1120 mm wide x 2355 mm high

Standard Pairs - Not allowed.

Double Egress - Not allowed.

This door is eligible for use with Anhui Meilin Kaidi - 90 Minute Steel Door Frame (Model GFM-MLKDas-L-1224 A90Mins).

The product noted above has been tested and qualified per UL 10B, UL 10C, NFPA 252 and CAN / ULC S104 for a 90 Minute Positive Pressure Fire Rating with Hose Stream.

The door noted above is eligible to bear the "S" (for Smoke & Draft Control assemblies) if a listed "Category H - Smoke & Draft Control Gasket" has been applied to the assembly. Please refer to Category H for individual gasket manufacturer's listings.

Party(s) Authorized by Manufacturer To Apply Mark:

Anhui Meilin Kaidi Wood Industry Co., Ltd
No 1 Road, Yingjiang Industrial Park
Yingjiang District
Anqing City, Anhui Province 246008
China
Contact: Yu Yue
Phone: (+86) 1995-5613652
Email: yy_809@outlook.com

Party(s) Authorized by Other Parties To Apply Mark:

None