AUTHORIZATION TO MARK

This authorizes the application of the Certification Mark(s) shown below to the models described in the Product(s) Covered section when made in accordance with the conditions set forth in the Certification Agreement and Listing Report(s). This authorization also applies to the Multiple Listee model(s) identified on the correlation page of the Listing Report.

This document is the property of Intertek Testing Services and is not transferable. The Certification Mark(s) may be applied only at the location of the Party Authorized to Apply Mark.

Applicant:	Anhui Meilin Kaidi Wood Industry Co., Ltd No 1 Road, Yingjiang Industrial Park Yingjiang District Anqing City, Anhui Province 246008 China
Contact:	Yu Yue
Phone:	(+86) 1995-5613652
Email:	yy_809@outlook.com
Party Authorized to Apply Mark:	See following page(s)
Evaluation Center:	Intertek (Shanghai)
Client Number:	459339

Authorized By:
Jean-Philippe Kayl, Director of Certification

Intertek Testing Services NA, Inc.
545 E. Algonquin Road, Ste H., Arlington Heights, IL 60005 USA
Phone: 847-439-5667 Fax: 847-439-7320

This document supersedes all previous Authorizations to Mark for the noted Report Number.

This Authorization to Mark is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Authorization to Mark. Only the Client is authorized to permit copying or distribution of this Authorization to Mark and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement and in this Authorization to Mark. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

Testing Standard(s):	CAN / ULC S104 (2015) (R2020), UL 10(b) (2008) (R2020), UL 10(c) (2016) Ed. 3 (R:27 May 2021), NFPA 252 (2022)
Product:	Anhui Meilin Kaidi - 90 Minute Steel Door Frame (Model GFM-MLKDas-L-1224 A90Mins)

ATM for Spec Id: 91996 **ATM Issue Date:** 8/20/2026

Listing Section(s): CATEGORY C - PROPRIETARY FRAMES

CSI Code(s): 08 10 00 Doors and Frames

Description:

FIRE DOOR FRAMES
Fixed Steel CATEGORY C - PROPRIETARY FRAMES for installation in 90 Minutes masonry or aerated concrete wall openings.

PRODUCT COVERED
Anhui Meilin Kaidi - 90 Minute Steel Door Frame
Model: GFM-MLKDas-L-1224 A90Mins

PRODUCT DESCRIPTION
Frame type: CATEGORY C - PROPRIETARY FRAMES

Frame stop: 15 mm high at header and jamb edges

Maximum Size of Openings:	Singles - 1130 mm wide x 2365 mm high Pairs - Not Allowed Double Egress – Not Allowed
Minimum Throat Opening:	84 mm

For use with Anhui Meilin Kaidi - 90 Minute Single Leaf Steel Fire door (Model GFM-MLKDas-L-1224 A90Mins).

Frames Evaluated to the Following:
Unless otherwise noted, assemblies in this section have been tested to the following standards:

CAN/ULC S104, Standard Method for Fire Tests of Door Assemblies;
NFPA-252, Standard Methods of Fire Tests of Door Assemblies;
UL-10B, Standard for Fire Tests of Door Assemblies;
UL-10C, Standard for Positive Pressure Fire Tests of Door Assemblies;
and are installed, unless otherwise noted, in accordance with the following:
NFPA-80, Standard for Fire Doors and Other Opening Protectives;
Manufacturer's Installation Instructions;

All frames are identified by either a label or embossed marking bearing the wording "Fire Door Frame" and the Intertek WH Certification Mark. Frames rated for less than 3 hours also bear the time interval.

Party(s) Authorized by Manufacturer To Apply Mark:

Anhui Meilin Kaidi Wood Industry Co., Ltd
No 1 Road, Yingjiang Industrial Park
Yingjiang District
Anqing City, Anhui Province 246008
China
Contact: Yu Yue
Phone: (+86) 1995-5613652
Email: yy_809@outlook.com

Party(s) Authorized by Other Parties To Apply Mark:

None