SpecDIRECT™ POWERED BY intertek

intertek
Total Quality. Assured.

LISTING INFORMATION OF

Anhui Meilin Kaidi - 20 Minute Single Leaf Wooden Fire Door with Hose Stream (Model MFM-MLKDas-L-1224 A20Mins)

SPEC ID: 92611

Anhui Meilin Kaidi Wood Industry Co., Ltd
No 1 Road, Yingjiang Industrial Park
Yingjiang District
Anqing City, Anhui Province 246008
China

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

LISTING INFORMATION

FIRE RESISTANT PRODUCTS & COMPONENTS
CATEGORY B DOORS - ADDITIONAL EDGE-SEALING SYSTEM REQUIRED
A mortise applied to frame Category G intumescent edge seal system is required.

PRODUCT COVERED
Anhui Meilin Kaidi - Single Leaf Wooden Fire Door
Model: MFM-MLKDas-L-1224 A20Mins

PRODUCT DESCRIPTION
Hardware Limitations:
Listed Mortise Lock or Cylindrical lock, dead bolt, surface-mounted rim exit device with minimum latch bolt throw of 1/2".
Minimum one single point standard latching on the leaf.

Configuration	Maximum Size
Single Swing	1100 mm wide by 2400 mm high (Nominal)

Standard Pairs - Not allowed.

Double Egress - Not allowed.

The product noted above has been tested and qualified per UL 10B, UL 10C, NFPA 252, and CAN / ULC S104 for a 20 Minute Positive Pressure Fire Rating with Hose Stream.

This door is eligible for use with Anhui Meilin Kaidi - 20 Minute Wooden Composite Door Frame (Model MFM-MLKDas-L-1224 A20Mins).

The door noted above is eligible to bear the "S" (for Smoke & Draft Control assemblies) if a listed "Category H - Smoke & Draft Control Gasket" has been applied to the assembly. Please refer to Category H for individual gasket manufacturer's listings.

Attribute	Value
Criteria	CAN / ULC S104 (2015) (R2020)
Criteria	UL 10(b) (2008) (R2020)
Criteria	UL 10(c) (2016) Ed. 3 (R:27 May 2021)
Criteria	NFPA 252 (2022)
CSI Code	08 10 00 Doors and Frames
Fire Resistance	20 Min w/Hose Stream PP Cat B Door
Intertek Services	Certification
Listed or Inspected	LISTED
Listing Section	CATEGORY B - DOORS - ADDITIONAL EDGE-SEALING SYSTEM REQUIRED
Report Number	250612025SHF

Spec ID	92611
Swing	Single Swing
Verification Test Type	ASTM E1252
Verification Testing	YES
Verification Testing Lab	GZU - Guangzhou, China