LISTING INFORMATION OF

Anhui Meilin Kaidi - 20 Minute Wooden Composite Door Frame with Hose Stream (Model MFM-MLKDas-L-1224 A20Mins)

SPEC ID: 92612

Anhui Meilin Kaidi Wood Industry Co., Ltd
No 1 Road, Yingjiang Industrial Park
Yingjiang District
Anqing City, Anhui Province 246008
China

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

LISTING INFORMATION

FIRE DOOR FRAMES
Wooden composite door frame for installation in 20 minute masonry or aerated concrete wall openings.

PRODUCT COVERED
Anhui Meilin Kaidi - 20 Minute Wooden Composite Door Frame
Model: MFM-MLKDas-L-1224 A20Mins

PRODUCT DESCRIPTION
Frame type: CATEGORY C - PROPRIETARY FRAMES

Frame stop: 18 mm high at header and jamb edges

Maximum Size of Openings:	Singles - 1106 mm wide x 2410 mm high Pairs - Not Allowed Double Egress – Not Allowed
Minimum Jamb Depth:	120 mm

Frames Evaluated to the Following:
Unless otherwise noted, assemblies in this section have been tested to the following standards:

CAN/ULC S104, Standard Method for Fire Tests of Door Assemblies;
NFPA-252, Standard Methods of Fire Tests of Door Assemblies;
UL-10B, Standard for Fire Tests of Door Assemblies;
UL-10C, Standard for Positive Pressure Fire Tests of Door Assemblies;
and are installed, unless otherwise noted, in accordance with the following:
NFPA-80, Standard for Fire Doors and Other Opening Protectives;
Manufacturer's Installation Instructions;

All frames are identified by either a label or embossed marking bearing the wording "Fire Door Frame" and the Intertek WH Certification Mark. Frames rated for less than 3 hours also bear the time interval.

Attribute	Value
Criteria	CAN / ULC S104 (2015) (R2020)
Criteria	UL 10(b) (2008) (R2020)
Criteria	UL 10(c) (2016) Ed. 3 (R:27 May 2021)
Criteria	NFPA 252 (2022)
CSI Code	08 10 00 Doors and Frames
Fire Resistance	20 Min PP Category C Proprietary Frame
Intertek Services	Certification
Listed or Inspected	LISTED
Listing Section	CATEGORY C - PROPRIETARY FRAMES
Report Number	250612025SHF

Spec ID	92612
Verification Test Type	ASTM E1252
Verification Testing	YES
Verification Testing Lab	GZU - Guangzhou, China